



	Non-Hazardous			Hazardous USP <800> (2020)				Radiopharmaceutical USP <825> (2020)		
	Non-Sterile Compounding USP <795> (2022)	Sterile Compounding USP <797> (2022)		HD Storage Room	Non-Sterile Compounding USP <795> (2022)	Sterile Compounding USP <797> (2022)		All		
	Any	Clean Suite	Unclassified SCA	Any	Any	Clean Suite	Unclassified C-SCA	Clean Suite	ISO 8 SRPA	Unclassified SRPA
TOTAL PARTICLE COUNTS	-	✓	-	-	-	✓	-	✓	✓	-
AIRFLOW TESTING	-	✓	-	✓	✓	✓	✓	✓	-	-
HEPA FILTER INTEGRITY TESTING	*	✓	*	*	*	✓	*	✓	*	*
PRESSURIZATION	-	✓	-	✓	✓	✓	✓	✓	✓	✓
VIABLE SAMPLING	-	✓	-	-	-	✓	-	✓	-	-
ROOM SMOKE STUDIES (When air returns are not low on the wall)	-	✓	-	-	-	✓	-	✓	-	-
TEMPERATURE & RELATIVE HUMIDITY	Optional	Optional	Optional	Optional	Optional	Optional	Optional	Optional	Optional	Optional
PERSONNEL COMPETENCY	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓

\* = HEPA filters are not a chapter requirement but will be tested if present.

ENV Legal Notice: This file is confidential and intended solely for the use of the individual or entity to whom they are distributed. If you are not the intended recipient you are notified that disclosing, copying, distributing or taking any action in reliance on the contents of this information is strictly prohibited.